

**ANTHONY WAYNE MIDDLE SCHOOL
201 GARSIDE AVE**

**KEY: TNR: TESTING NOT REQUIRED
DEP & EPA STANDARD LEAD LEVEL: 15.000 PARTS PER BILLION
ND: None Detected BS: Below DEP/EPA Standard**

Test Date - 10/22/16

SAMPLE NUMBER	DESCRIPTION	TEST RESULTS	NOTES
L6525179-1	KITCHEN SINK SMALL BACK WALL	ND	ND
L6525179-2	TEACHERS ROOM SINK	ND	ND
L6525179-3	KITCHEN SINK BACK WALL RIGHT	ND	ND
L6525179-4	SCIENCE ROOM 101 ISLAND 2 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-5	CAFETERIA FOUNTAIN LEFT	ND	ND
L6525179-6	MAIN OFFICE SINK	ND	ND
L6525179-7	KITCHEN SINK BACK WALL SMALL ONE	1.100	BS
L6525179-8	KITCHEN SINK BACK WALL FAR RIGHT	ND	ND
L6525179-9	FOUNTAIN RIGHT BY ROOM 101 SC	ND	ND
L6525179-10	KITCHEN SINK BACK WALL LEFT	ND	ND
L6525179-11	SCIENCE ROOM 101 ISLAND 1 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-12	FOUNTAIN RIGHT BY ROOM 112 SC	ND	ND
L6525179-13	NURSES OFFICE SINK	ND	ND
L6525179-14	SCIENCE ROOM 101 ISLAND 2 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-15	SCIENCE ROOM 101 ISLAND 2 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-16	KITCHEN SINK SMALL ISLAND	4.600	BS
L6525179-17	WOOD SHOP SINK RIGHT	2.000	BS/TNR
L6525179-18	GYM FOUNTAIN LEFT BY BOYS LOCKER ROOM	ND	ND
L6525179-19	FOUNTAIN LEFT BY ROOM 100 SC	ND	ND
L6525179-20	CAFETERIA FOUNTAIN RIGHT	ND	ND
L6525179-21	NURSES OFFICE BATHROOM SINK	ND	ND
L6525179-22	GIRLS LOCKER ROOM FOUNTAIN	ND	ND
L6525179-23	SCIENCE ROOM 112 ISLAND 2 SINK RIGHT	7.200	BS/TNR
L6525179-24	SCIENCE ROOM 112 ISLAND 3 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-25	SCIENCE ROOM 112 ISLAND 4 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-26	SCIENCE ROOM 101 ISLAND 3 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-27	SCIENCE ROOM 101 ISLAND 6 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-28	SCIENCE ROOM 101 ISLAND 5 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-29	KITCHEN SINK ON LARGE ISLAND	ND	ND
L6525179-30	SCIENCE ROOM 101 ISLAND 5 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-31	SCIENCE ROOM 112 ISLAND 1 SINK RIGHT	6.900	BS/TNR
L6525179-32	SCIENCE ROOM 112 ISLAND 2 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-33	WOOD SHOP SINK LEFT	4.700	BS/TNR
L6525179-34	BOYS LOCKER ROOM FOUNTAIN	ND	ND
L6525179-35	SCIENCE ROOM 101 SINK FRONT	TNR	TNR-SIGN POSTED
L6525179-36	GYM FOUNTAIN RIGHT BY BOYS LOCKER ROOM	ND	ND
L6525179-37	FOUNTAIN LEFT BY 111 SC	ND	ND

**ANTHONY WAYNE MIDDLE SCHOOL
201 GARSIDE AVE**

**KEY: TNR: TESTING NOT REQUIRED
DEP & EPA STANDARD LEAD LEVEL: 15.000 PARTS PER BILLION
ND: None Detected BS: Below DEP/EPA Standard**

Test Date - 10/22/16

L6525179-38	SCIENCE ROOM 101 ISLAND 1 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-39	SCIENCE ROOM 112 BACK WALL SINK	10.500	BS/TNR
L6525179-40	SCIENCE ROOM 201 ISLAND 6 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-41	SCIENCE LAB 201 ISLAND 1 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-42	SCIENCE LAB 112 FRONT SINK	4.200	BS/TNR
L6525179-43	MEDIA CENTER FOUNTAIN LEFT	ND	ND
L6525179-44	SCIENCE LAB 201 ISLAND 5 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-45	BOYS LOCKER ROOM OFFICE SINK	ND	ND
L6525179-46	GIRLS LOCKER ROOM OFFICE SINK	ND	ND
L6525179-47	SCIENCE ROOM 112 ISLAND 5 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-48	SCIENCE ROOM 112 ISLAND 1 SINK LEFT	4.800	BS/TNR
L6525179-49	GYM FOUNTAIN RIGHT BY MEDIA CENTER	ND	ND
L6525179-50	SCIENCE ROOM 112 ISLAND 6 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-51	MEDIA CENTER FOUNTAIN RIGHT	ND	ND
L6525179-52	SCIENCE ROOM 101 ISLAND 4 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-53	SCIENCE ROOM 112 ISLAND 5 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-54	SCIENCE ROOM 101 BACK WALL SINK	TNR	TNR-SIGN POSTED
L6525179-55	PREP ROOM 101 SINK	7.400	BS/TNR
L6525179-56	PREP ROOM 201 SINK	1.9	BS/TNR
L6525179-57	MEDIA CENTER OFFICE SINK	ND	ND
L6525179-58	SCIENCE ROOM 201 ISLAND 4 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-59	GYM FOUNTIAN LEFT BY MEDIA CENTER	ND	ND
L6525179-60	SCIENCE ROOM 112 ISLAND 6 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-61	SCIENCE ROOM 112 ISLAND 4 SINK RIGHT	7.200	BS/TNR
L6525179-62	SCIENCE ROOM 101 ISLAND 6 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-63	HOME EC STATION 3 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-64	SCIENCE ROOM 101 ISLAND 4 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-65	SCIENCE ROOM 201 ISLAND 5 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-66	HOME EC STATION 3 SINK RIGHT	2.700	BS
L6525179-67	SCIENCE ROOM 201 ISLAND 2 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-68	SCIENCE ROOM 214 SINK FRONT	5.100	BS/TNR
L6525179-69	SCIENCE ROOM 201 ISLAND 3 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-70	ART ROOM 213 SINK LEFT	1.300	BS/TNR
L6525179-71	SCIENCE ROOM 214 ISLAND 6 SINK RIGHT	13.000	BS/TNR
L6525179-72	FOUNTAIN LEFT BY SCIENCE ROOM 201	ND	ND
L6525179-73	SCIENCE ROOM 201 BACK SINK	3.200	BS/TNR
L6525179-74	ART ROOM 212 SINK LEFT	ND	ND
L6525179-75	SCIENCE ROOM 214 ISLAND 5 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-76	SCIENCE ROOM 214 ISLAND 4 SINK LEFT	TNR	TNR-SIGN POSTED

**ANTHONY WAYNE MIDDLE SCHOOL
201 GARSIDE AVE**

KEY: TNR: TESTING NOT REQUIRED
DEP & EPA STANDARD LEAD LEVEL: 15.000 PARTS PER BILLION
ND: None Detected BS: Below DEP/EPA Standard
Test Date - 10/22/16

L6525179-77	SCIENCE ROOM 201 ISLAND 6 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-78	FOUNTAIN RIGHT BT SCIENCE ROOM 201	ND	ND
L6525179-79	HOME EC STATION 1 SINK RIGHT	1.700	BS
L6525179-80	SCIENCE ROOM 214 ISLAND 5 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-81	SCIENCE ROOM 201 FRONT SINK	8.300	BS/TNR
L6525179-82	SCIENCE ROOM 214 SINK BACK	7.300	BS/TNR
L6525179-83	HOME EC STATION 1 SINK LEFT	ND	ND
L6525179-84	SCIENCE ROOM 214 ISLAND 6 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-85	SCIENCE ROOM 214 ISLAND 2 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-86	SCIENCE ROOM 214 ISLAND 4 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-87	ART ROOM 212 SINK RIGHT	ND	ND
L6525179-88	FOUNTAIN LEFT BY ROOM 217	ND	ND
L6525179-89	SCIENCE ROOM 214 ISLAND 3 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-90	SCIENCE ROOM 214 ISLAND 1 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-91	HOME EC STATION 2 SINK LEFT	TNR	SIGN POSTED
L6525179-92	HOME EC STATION 2 SINK RIGHT	2.800	BS
L6525179-93	SCIENCE ROOM 201 ISLAND 4 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-94	SCIENCE ROOM 214 ISLAND 3 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-95	ART ROOM 213 SINK RIGHT	1.400	BS/TNR
L6525179-96	SCIENCE ROOM 214 ISLAND 2 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-97	SCIENCE ROOM 201 ISLAND 3 SINK RIGHT	TNR	TNR-SIGN POSTED
L6525179-98	SCIENCE ROOM 201 ISLAND 1 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-99	SCIENCE ROOM 201 ISLAND 2 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-100	SCIENCE ROOM 214 ISLAND 1 SINK LEFT	TNR	TNR-SIGN POSTED
L6525179-101	FOUNTAIN RIGHT BT ROOM 217	ND	ND